## DESIGN NOTES CDS-3-C (CDS1515)



FOLLOWING U.S.

STANDARD CDS-3-C CONFIGURATION.



FRAME AND COVER

(DIAMETER VARIES) N.T.S. GENERAL NOTES 1. SOLENO TO PROVIDE ALL MATERIALS UNLESS NOTED OTHERWISE

9025 Centre Pointe Dr., Suite 400, West Chester, OH 45069 800-338-1122 513-645-7000 513-645-7993 FAX

**ENGINEERED SOLUTIONS LLC** 

www.contechES.com

NECESSARY DURING MAINTENANCE CLEANING.

SPECIFIED BY ENGINEER OF RECORD.

INSTALLATION NOTES

Β.

C.

D.

## SITE SPECIFIC **DATA REQUIREMENTS**

STRUCTURE ID						
WATER QUALITY FLOW RATE (L/s)					*	
PEAK FLOW RATE (L/s)					*	
RETURN PERIOD OF PEAK FLOW (YRS)					*	
SCREEN APERTURE (2400 OR 4700)					*	
PIPE DATA:	I.E.	MATERIAL		D	DIAMETER	
INLET PIPE 1	*	*		*		
INLET PIPE 2	*	*		*		
OUTLET PIPE	*	*		*		
RIM ELEVATION					*	
ANTI-FLOTATION BALLAST			WIDTH		HEIGHT	
			*		*	
NOTES/SPECIAL REQUIREMENTS:						
* PER ENGINEER OF RECORD						

A. ANY SUB-BASE, BACKFILL DEPTH, AND/OR ANTI-FLOTATION PROVISIONS ARE SITE-SPECIFIC DESIGN CONSIDERATIONS AND SHALL BE

CONTRACTOR TO PROVIDE EQUIPMENT WITH SUFFICIENT LIFTING AND REACH CAPACITY TO LIFT AND SET THE CDS MANHOLE STRUCTURE.

E. CONTRACTOR TO TAKE APPROPRIATE MEASURES TO ASSURE UNIT IS WATER TIGHT, HOLDING WATER TO FLOWLINE INVERT MINIMUM.

6. CDS STRUCTURE SHALL BE PRECAST CONCRETE CONFORMING TO BNQ3622-420 AND BNQ 1809-300.

CONTRACTOR TO PROVIDE, INSTALL, AND GROUT INLET AND OUTLET PIPE(S).

CONTRACTOR TO INSTALL JOINT SEALANT BETWEEN ALL STRUCTURE SECTIONS AND ASSEMBLE STRUCTURE.

2. FOR SITE SPECIFIC DRAWINGS WITH DETAILED STRUCTURE DIMENSIONS AND WEIGHT, PLEASE CONTACT YOUR SOLENO ENGINEER 3. CDS WATER QUALITY STRUCTURE SHALL BE IN ACCORDANCE WITH ALL DESIGN DATA AND INFORMATION CONTAINED IN THIS DRAWING. CONTRACTOR TO CONFIRM STRUCTURE MEETS REQUIREMENTS OF PROJECT.

4. STRUCTURE SHALL MEET CL-625 LOAD RATING (CAN/CSA-S6), ASSUMING EARTH COVER OF 300 MM (12')', AND GROUNDWATER ELEVATION AT, OR BELOW, THE OUTLET PIPE INVERT ELEVATION. ENGINEER OF RECORD TO CONFIRM ACTUAL GROUNDWATER ELEVATION. BNQ2622-420

IDENTIFICATION AND THE CONTECH LOGO WILL BE STAMPED ON EACH PART OF THE PRECAST CONCRETE STRUCTURE.

5. IF REQUIRED, PVC HYDRAULIC SHEAR PLATE IS PLACED ON SHELF AT BOTTOM OF SCREEN CYLINDER. REMOVE AND REPLACE AS

CDS-3-C (CDS1515)

**ONLINE CDS** 

STANDARD DETAIL